

**Extinguishing System**  
**Plan Review Requirements**

*Three (3) sets of plans and specifications signed and sealed by a registered design professional licensed in the state where the construction is to be performed.*

- Amount and type of agent in system.
- Size, length and arrangement of piping.
- Description and location of nozzles.
- Location and function of detection devices.
- Locations and function of operating devices.
- Flow rates of nozzles.
- Type of fire extinguisher(s).
- Cleaning schedule.
- Material designation.

Dry Chemical Extinguishing System, NFPA 17

Wet Chemical Extinguishing System, NFPA 17A

Carbon Dioxide Extinguishing System, NFPA 12

Sprinkler Extinguishing System, NFPA 13